

30 May 2008

GRAVES COUNTY KENTUCKY
FARM SERVICE AGENCY
COMMONWEALTH DRIVE
MAYFIELD, KENTUCKY 42066



ADDENDUM NO. TWO

TO PLANHOLDERS: This addendum is issued to modify the original drawings, and is hereby made part of the contract documents. Please attach this addendum to the drawings in your possession. Review changes to each portion of the work, as changes of one portion may affect the work of another.

ITEM 01

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 2 - SITE WORK; Add the following: "Rough grading shall be 'N.I.C.' or 'Provided by Others'." CLARIFICATION: Notify the Owner of any depressions and/or soft spots found in the building pad prior to construction.

ITEM 02

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 2 - SITE WORK, Termite Control; CLARIFICATION: Work under this specification shall be included in Base Bid.

ITEM 03

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 7 - THERMAL AND MOISTURE PROTECTION, Thermoplastic Membrane Roofing System; Delete "Fully adhered". Substitute therefor, "Mechanically attached". CLARIFICATION: Roofing system shall be manufacturer's standard mechanically attached system throughout.

ITEM 04

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 9 - FINISHES; Add the following: "Work under this specification, shall be 'N.I.C.' or 'Provided by Others'."

ITEM 05

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 10 - SPECIALTIES, Picture Rail; CLARIFICATION: Picture Rail shall be "N.I.C." or "Provided by Others".

ITEM 06

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 10 - SPECIALTIES, Architectural Louvers; CLARIFICATION: Architectural Louvers, shall be "N.I.C." or "Provided by Others".

ITEM 07

SHEET G001, OUTLINE SPECIFICATIONS, DIVISION 12 - FURNISHINGS; CLARIFICATION: Window Shades shall be "N.I.C." or "Provided by Others".

ITEM 08

SHEET S100, PROJECT SPECIFICATIONS, CONCRETE WORK; Delete references to "curing compound" in their entirety. CLARIFICATION: Cure-N-Seal and other chemical curing compounds are not permitted. Curing shall be by moisture-curing as specified.

ITEM 09

SHEET S102, DRAWING C1 - FOUNDATION PLAN, Column A5; Add the following note: "HSS4x4x1/4".

ITEM 10

SHEET S201, TYP. DETAIL - ROOF OPENING; Add the following note: "2 THUS". CLARIFICATION: In addition to opening frame shown at ROOF HATCH, coordinate location and provide opening frame at N.I.C. CURB-MOUNT HVAC FRESH AIR INTAKE UNIT, not shown.

END OF ADDENDUM NO. TWO